

VOC Content Test Certificate

Wednesday March 16th, 2010

Manufacturer: RLA Polymers Pty Ltd. (PO Box 147 Kilsyth Vic 3137)

Sample Description: Flexiseal Pud (Water Proofing Membrane)

Date Tested: March 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	FLEXISEAL PUD
Green Building Council of Australia	
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
Architectural Sealant 250 grams per Litre	<2 grams per Litre
Specification	FLEXISEAL PUD
Green Building Council of Australia	
Green Star Office Design V3 IEQ-13	
Architectural Sealant 250 grams per Litre	<2 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1003-06